

CERTIFICATE OF COMPLIANCE

Certificate Number 20180222-EX27593
Report Reference EX27593-20180220
Issue Date 2018-FEBRUARY-22

Issued to: Mitr Steel Co., Ltd
114/40 Moo 10 Tambon Nhonglalork Amphur Ban-Kyai
Rayong 21120 THAILAND

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE


Schedule 40 (Black or Galvanized) steel sprinkler pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6 & 8 in sizes, as per ASTM A53/A53M-12, Grade A & B Type E
All the above pipes are ERW and are constructed from hot rolled steel coils that conform to ASTM standards as indicated above.
All pipes with threaded ends shall conform to ANSI B1.20.1.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 - Metallic Sprinkler Pipe for Fire Protection Service
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

